

## Radon Testing

The following summary provides results of radon testing performed at this location.

Room	Start	Stop	Result	Variance	Comment
MAIN OFFICE	2017/04/10	2017/04/13	1.2	0.3	
BLANK	2017/04/10	2017/04/13	<0.3	0.3	
PRINCIPALS OFFIE	2017/04/10	2017/04/13	1	0.3	
CONFERENCE ROOM	2017/04/10	2017/04/13	0.8	0.3	
GYM-1	2017/04/10	2017/04/13	< 0.3	0.3	
GYM-2	2017/04/10	2017/04/13	0.6	0.3	
CUSTODIAN	2017/04/10	2017/04/13	1.5	0.4	
CUSTODIAN-DUP.	2017/04/10	2017/04/13	1.5	0.4	
LIBRARY	2017/04/10	2017/04/13	1.1	0.3	
LIBRARY	2017/04/10	2017/04/13	1.1	0.3	
WORK ROOM	2017/04/10	2017/04/13	1.2	0.3	
PTC OFFICE	2017/04/10	2017/04/13	1.2	0.3	
COOK'S OFFICE	2017/04/10	2017/04/13	1.4	0.3	
CAFETERIA-1	2017/04/10	2017/04/13	1.1	0.3	
CAFETERIA-2	2017/04/10	2017/04/13	0.8	0.3	
COMPUTER LAB	2017/04/10	2017/04/13	<0.3	0.3	
MUSIC	2017/04/10	2017/04/13	<0.3	0.3	
17 STAFF LOUNGE	2017/04/10	2017/04/13	1	0.3	
16	2017/04/10	2017/04/13	<0.3	0.3	
7	2017/04/10	2017/04/13	0.8	0.3	
6	2017/04/10	2017/04/13	0.8	0.3	
5	2017/04/10	2017/04/13	<0.3	0.3	
4	2017/04/10	2017/04/13	0.8	0.3	
3	2017/04/10	2017/04/13	0.6	0.3	
2	2017/04/10	2017/04/13	<0.3	0.3	
2-DUP	2017/04/10	2017/04/13	0.8	0.3	
1	2017/04/10	2017/04/13	<0.3	0.3	