


EO	TEST# 1 First Flow	TEST# 2 30 Sec Flush	TEST# 3 After action	Action required Y/N	Passed Below 20/ppb Y/N	Remediation	SAMPLE NAME	BUILDING LOCATION	Lab Name	LAB SAMP ID	SAMPLE DATE	PREP DATE	ANA DATE	BATCH	Result target <20ppb		
															ND= non detect	UNITS	COST PER SAMPLE
EO	X				Y		EO 601	Classroom 1	Apex Laborat	A6F0137-57	6/2/16	6/7/16	6/8/16	6060204	8.56	ug/L	\$15.00
EO	X				Y		EO 602	Classroom 2	Apex Laborat	A6F0137-58	6/2/16	6/7/16	6/8/16	6060204	6.39	ug/L	\$15.00
EO	X				Y		EO 603	Classroom 3	Apex Laborat	A6F0137-59	6/2/16	6/7/16	6/8/16	6060204	5.94	ug/L	\$15.00
EO	X				Y		EO 604	Classroom 4	Apex Laborat	A6F0137-60	6/2/16	6/7/16	6/8/16	6060204	4.27	ug/L	\$15.00
EO	X				Y		EO 604A	Fountain North Hall	Apex Laborat	A6F0137-61	6/2/16	6/7/16	6/8/16	6060205	1.33	ug/L	\$15.00
EO	X				Y		EO 605	Classroom 5	Apex Laborat	A6F0137-62	6/2/16	6/7/16	6/8/16	6060205	6.25	ug/L	\$15.00
EO	X				Y		EO 606	Classroom 6	Apex Laborat	A6F0137-63	6/2/16	6/7/16	6/8/16	6060205	14.7	ug/L	\$15.00
EO		X			Y		EO 606 6/16F	Classroom 6	Apex Laborat	A6F0629-04	6/2/16	6/27/16	6/27/16	6060793	5.88	ug/L	\$15.00
EO	X				Y	Replaced Faucet	EO 607	Classroom 7	Apex Laborat	A6F0137-64	6/2/16	6/7/16	6/8/16	6060205	18.6	ug/L	\$15.00
EO		X			N	Replaced supply line	EO 607 6/16F	Classroom 7	Apex Laborat	A6F0629-02	6/2/16	6/30/16	6/30/16	6060933	66.3	ug/L	\$15.00
EO	X				Y		EO-607	Classroom 7	N Lab	A6H0465-01	8/8/16	8/16/16	8/16/16		2.64	ug/L	\$25.00
EO	X				Y		EO 607A	Fountain Center Hall East end Left	Apex Laborat	A6F0137-65	6/2/16	6/7/16	6/8/16	6060205	3.58	ug/L	\$15.00
EO	X				Y		EO 607B	Fountain Center Hall East end Right	Apex Laborat	A6F0137-66	6/2/16	6/7/16	6/8/16	6060205	1.15	ug/L	\$15.00
EO	X				Y		EO 608	Classroom 8	Apex Laborat	A6F0137-67	6/2/16	6/7/16	6/8/16	6060205	1.26	ug/L	\$15.00
EO	X				Y		EO 609	Classroom 9	Apex Laborat	A6F0137-68	6/2/16	6/7/16	6/8/16	6060205	2.30	ug/L	\$15.00
EO	X				Y		EO 610	Classroom 10	Apex Laborat	A6F0137-69	6/2/16	6/7/16	6/8/16	6060205	0.909	ug/L	\$15.00
EO	X				Y		EO 611	Classroom 11	Apex Laborat	A6F0137-70	6/2/16	6/7/16	6/8/16	6060205	5.74	ug/L	\$15.00
EO	X				Y		EO 612	Classroom 12	Apex Laborat	A6F0137-71	6/2/16	6/7/16	6/8/16	6060205	4.44	ug/L	\$15.00
EO	X				Y		EO 613	Classroom 13	Apex Laborat	A6F0137-72	6/2/16	6/7/16	6/8/16	6060205	7.44	ug/L	\$15.00
EO	X				Y		EO 613A	Fountain Outside Center Hall West end	Apex Laborat	A6F0137-73	6/2/16	6/7/16	6/8/16	6060205	1.24	ug/L	\$15.00
EO	X				Y		EO 614	Fountain Gym	Apex Laborat	A6F0137-75	6/2/16	6/7/16	6/8/16	6060205	1.33	ug/L	\$15.00
EO	X				Y		EO 614A	Classroom 14	Apex Laborat	A6F0137-74	6/2/16	6/7/16	6/8/16	6060205	1.39	ug/L	\$15.00
EO	X				Y		EO 615	Classroom 15	Apex Laborat	A6F0137-76	6/2/16	6/7/16	6/8/16	6060205	4.50	ug/L	\$15.00
EO	X				Y		EO 616	Classroom 16	Apex Laborat	A6F0137-77	6/2/16	6/7/16	6/8/16	6060205	2.06	ug/L	\$15.00
EO					Y		EO 616A	Fountain South Hall	Apex Laborat	A6F0137-78	6/2/16	6/7/16	6/8/16	6060205	1.42	ug/L	\$15.00
EO	X				Y		EO 617	Classroom 17	Apex Laborat	A6F0137-79	6/2/16	6/7/16	06/08/2016	6060205	16.6	ug/L	\$15.00
EO		X			Y		EO 617 6/16F	Classroom 17	Apex Laborat	A6F0629-01	6/20/16	6/27/16	06/27/2016	6060793	1.26	ug/L	\$15.00
EO	X				Y		EO 618	Classroom 18	Apex Laborat	A6F0137-80	6/2/16	6/7/16	06/08/2016	6060205	16.3	ug/L	\$15.00
EO		X			Y		EO 618 6/16F	Classroom 18	Apex Laborat	A6F0629-03	6/20/16	6/27/16	06/27/2016	6060793	5.38	ug/L	\$15.00
EO	X				Y		EO 619	Kindergarten Rm.	Apex Laborat	A6F0137-81	6/2/16	6/7/16	06/08/2016	6060206	1.87	ug/L	\$15.00
EO	X				Y		EO 619A	Fountain Café	Apex Laborat	A6F0137-82	6/2/16	6/7/16	06/08/2016	6060206	5.74	ug/L	\$15.00
EO	X				Y		EO 620	Kitchen Sink North Left	Apex Laborat	A6F0137-83	6/2/16	6/7/16	06/08/2016	6060206	5.59	ug/L	\$15.00
EO	X				Y		EO 621	Kitchen Sink North Right	Apex Laborat	A6F0137-84	6/2/16	6/7/16	06/08/2016	6060206	1.70	ug/L	\$15.00
EO	X				Y		EO 622	Kitchen 3 compartment sink	Apex Laborat	A6F0137-85	6/2/16	6/7/16	06/08/2016	6060206	7.13	ug/L	\$15.00
EO	X				Y		EO 622A	Fountain Office Main Hall Left	Apex Laborat	A6F0137-86	6/2/16	6/7/16	06/08/2016	6060206	0.185	ug/L	\$15.00
EO	X				Y		EO 622B	Fountain Office Main Hall Right	Apex Laborat	A6F0137-87	6/2/16	6/7/16	06/08/2016	6060206	0.213	ug/L	\$15.00
EO	X				Y		EO 650	Ice Machine - Staff Room	Apex Laborat	A6I0953-67	9/1/16	10/5/16	10/06/2016	6100244	5.40	ug/L	\$25.00
EO	X				N	Labled not for Drinking	EO 651	Ext Hose Bib - Outside Main Office	Apex Laborat	A6I0953-86	9/1/16	10/5/16	10/05/2016	6100246	79.9	ug/L	\$25.00
EO		X			Y		EO 651F	Ext Hose Bib - Outside Main Office	Apex Laborat	A6I0953-87	9/1/16	10/5/16	10/05/2016	6100246	0.274	ug/L	\$25.00
EO	X				Y		EO 652	Ext Hose Bib - Outside Counseling Office	Apex Laborat	A6I0953-68	9/1/16	10/5/16	10/06/2016	6100244	14.8	ug/L	\$25.00
EO		X			Y		EO 652F	Ext Hose Bib - Outside Counseling Office	Apex Laborat	A6I0953-73	9/1/16	10/5/16	10/06/2016	6100244	1.62	ug/L	\$25.00
EO	X				Y	Labled not for Drinking	EO 653	Ext Hose Bib - Outside Computer Lab	Apex Laborat	A6I0953-69	9/1/16	10/5/16	10/06/2016	6100244	26.2	ug/L	\$25.00
EO		X			Y		EO 653F	Ext Hose Bib - Outside Computer Lab	Apex Laborat	A6I0953-74	9/1/16	10/5/16	10/06/2016	6100244	0.444	ug/L	\$25.00
EO	X				N	Labled not for Drinking	EO 654	Ext Hose Bib - Outside Restrooms	Apex Laborat	A6I0953-70	9/1/16	10/10/16	10/11/2016	6100386	240	ug/L	\$25.00
EO		X			Y		EO 654F	Ext Hose Bib - Outside Restrooms	Apex Laborat	A6I0953-75	9/1/16	10/5/16	10/06/2016	6100244	ND	ug/L	\$25.00



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45

46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63