

	TEST# 1 First Flow	TEST# 2 30 Sec Flush	TEST# 3 After action	Action required Y/N	Passed Below 20/ppm Y/N	Remediation	SAMPLE NAME	BUILDING LOCATION	Lab Name	LAB SAMP ID	SAMPLE DATE	PREP DATE	ANA DATE	BATCH	Result target <20ppb		
															ND= non detect	UNITS	COST PER SAMPLE
GHS	X				Y		GHS 1	Bottle Filler Hallway Main Office	Apex Labora	A6F0138-AA	6/2/16	6/10/16	6/13/16	6060335	ND	ug/L	\$15.00
GHS	X				Y		GHS 2	Bottle Filler Cafeteria	Apex Labora	A6F0139-01	6/2/16	6/10/16	6/13/16	6060335	ND	ug/L	\$15.00
GHS	X				Y		GHS 3	Bubbler Cafeteria	Apex Labora	A6F0139-02	6/2/16	6/10/16	6/13/16	6060335	0.271	ug/L	\$15.00
GHS	X				Y		GHS 4	Fountain Hallway Lower East Wing	Apex Labora	A6F0139-03	6/2/16	6/10/16	6/13/16	6060335	ND	ug/L	\$15.00
GHS	X				Y		GHS 5	Fountain Hallway Upper East Wing	Apex Labora	A6F0139-04	6/2/16	6/10/16	6/13/16	6060335	ND	ug/L	\$15.00
GHS	X				Y		GHS 6	Fountain Hallway by Rm. 202	Apex Labora	A6F0139-05	6/2/16	6/10/16	6/13/16	6060335	0.387	ug/L	\$15.00
GHS	X				Y		GHS 7	Fountain Girls Locker Rm.	Apex Labora	A6F0139-06	6/2/16	6/10/16	6/13/16	6060335	3.69	ug/L	\$15.00
GHS	X				Y		GHS 8	Bubbler Auxiliary Gym	Apex Labora	A6F0139-07	6/2/16	6/10/16	6/13/16	6060335	0.551	ug/L	\$15.00
GHS	X				Y		GHS 9	Fountain Fishbowl	Apex Labora	A6F0139-08	6/2/16	6/10/16	6/13/16	6060335	ND	ug/L	\$15.00
GHS	X				Y		GHS 10	Fountain Weight Rm.	Apex Labora	A6F0139-09	6/2/16	6/10/16	6/13/16	6060335	ND	ug/L	\$15.00
GHS	X				Y		GHS 11	Kitchen Prep Sink	Apex Labora	A6F0139-10	6/2/16	6/10/16	6/13/16	6060335	1.39	ug/L	\$15.00
GHS	X				Y		GHS 12	Faculty Break Rm. Sink	Apex Labora	A6F0139-11	6/2/16	6/10/16	6/13/16	6060335	0.753	ug/L	\$15.00
GHS	X				Y		GHS 13	Fountain next to Music Rm.	Apex Labora	A6F0139-12	6/2/16	6/10/16	6/13/16	6060335	1.36	ug/L	\$15.00
GHS	X				Y		GHS 14	Custodial Office Sink	Apex Labora	A6F0139-13	6/2/16	6/10/16	6/13/16	6060335	1.69	ug/L	\$15.00
GHS	X				Y		GHS 15	Fountain Childcare Hallway	Apex Labora	A6F0139-14	6/2/16	6/10/16	6/13/16	6060335	1.02	ug/L	\$15.00
GHS	X				Y		GHS 16	Childcare Changing Area Sink	Apex Labora	A6F0139-15	6/2/16	6/10/16	6/13/16	6060336	2.67	ug/L	\$15.00
GHS	X				Y		GHS 17	Sink in room next to changing area	Apex Labora	A6F0139-16	6/2/16	6/10/16	6/13/16	6060336	0.678	ug/L	\$15.00
GHS	X				Y		GHS 18	Exterior Hose Bib - Softball	Apex Labora	A6I0419-66	8/31/16	9/30/16	10/4/16	6091181	11.1	ug/L	\$25.00
GHS		X			Y		GHS 18F	Exterior Hose Bib - Softball	Apex Labora	A6I0419-69	8/31/16	9/30/16	10/4/16	6091181	0.459	ug/L	\$25.00
GHS	X				Y		GHS 19	Exterior Hose Bib - Baseball	Apex Labora	A6I0419-67	8/31/16	9/30/16	10/4/16	6091181	17.7	ug/L	\$25.00
GHS		X			Y		GHS 19F	Exterior Hose Bib - Baseball	Apex Labora	A6I0419-70	8/31/16	9/30/16	10/4/16	6091181	0.240	ug/L	\$25.00
GHS	X				Y		GHS 20	Exterior Hose Bib - East 300 Bldg.	Apex Labora	A6I0419-68	8/31/16	9/30/16	10/4/16	6091181	0.859	ug/L	\$25.00
GHS		X			Y		GHS 20F	Exterior Hose Bib - East 300 Bldg.	Apex Labora	A6I0419-71	8/31/16	9/30/16	10/4/16	6091181	0.272	ug/L	\$25.00
GHS	X				N	Labeled not for Drinking	GHS 21	Exterior Hose Bib - South 300 Bldg.	Apex Labora	A6I0419-72R	8/31/16	9/30/16	10/4/16	6091181	41.1	ug/L	\$25.00
GHS		X			Y		GHS 21F	Exterior Hose Bib - South 300 Bldg.	Apex Labora	A6I0419-73	8/31/16	9/30/16	10/4/16	6091181	5.37	ug/L	\$25.00
GHS	X				Y		GHS 22	Ice Machine - Kitchen	Apex Labora	A6I0419-74	8/31/16	10/5/16	10/5/16	6100231	1.48	ug/L	\$25.00
GHS	X				Y		GHS 23	Ice Machine - Training Rm.	Apex Labora	A6I0419-75	8/31/16	9/30/16	10/4/16	6091182	1.04	ug/L	\$25.00
GHS	X				Y		GHS 24	Sink - Custodial Closet (Fish Bowl)	Apex Labora	A6I0419-76	8/31/16	9/30/16	10/4/16	6091182	2.57	ug/L	\$25.00
GHS		X			Y		GHS 24F	Sink - Custodial Closet (Fish Bowl)	Apex Labora	A6I0419-78	8/31/16	9/30/16	10/4/16	6091182	ND	ug/L	\$25.00
GHS	X				Y		GHS 25	Soccer Locker Room - East of Aux Gym	Apex Labora	A6I0419-77R	8/31/16	9/30/16	10/4/16	6091182	0.209	ug/L	\$25.00
GHS		X			Y		GHS 25F	Soccer Locker Room - East of Aux Gym	Apex Labora	A6I0419-79	8/31/16	9/30/16	10/4/16	6091182	ND	ug/L	\$25.00
GHS	X				Y		GHS 26	Exterior Hose Bib - Outside Concession Stand	Apex Labora	A6I0419-80	8/31/16	9/30/16	10/4/16	6091182	14.4	ug/L	\$25.00
GHS		X			Y		GHS 26F	Exterior Hose Bib - Outside Concession Stand	Apex Labora	A6I0419-83	8/31/16	9/30/16	10/4/16	6091182	ND	ug/L	\$25.00
GHS	X				Y	Replaced faucet	GHS 27	Sink - Concession Stand (Fish Bowl)	Apex Labora	A6I0419-81	8/31/16	9/30/16	10/4/16	6091182	19.5	ug/L	\$25.00
GHS		X			Y		GHS 27F	Sink - Concession Stand (Fish Bowl)	Apex Labora	A6I0419-84	8/31/16	9/30/16	10/4/16	6091182	ND	ug/L	\$25.00
GHS	X				Y		GHS 28	Sink - Training Rm.	Apex Labora	A6I0419-82	8/31/16	9/30/16	10/4/16	6091182	3.16	ug/L	\$25.00
GHS		X			Y		GHS 28F	Sink - Training Rm.	Apex Labora	A6I0419-85	8/31/16	9/30/16	10/4/16	6091182	ND	ug/L	\$25.00
GHS	X				Y		GHS 29	Sink - Boys Locker Room	Apex Labora	A6I0419-86	8/31/16	9/30/16	10/4/16	6091182	6.79	ug/L	\$25.00
GHS		X			Y		GHS 29F	Sink - Boys Locker Room	Apex Labora	A6I0419-88	8/31/16	9/30/16	10/4/16	6091182	ND	ug/L	\$25.00
GHS	X				Y		GHS 30	Sink - Girls Locker Room	Apex Labora	A6I0419-87	8/31/16	9/30/16	10/4/16	6091182	3.24	ug/L	\$25.00
GHS	X				Y		GHS 31	Exterior Hose Bib - Grounds Shop Concession Stand	Apex Labora	A6I0419-89	8/31/16	9/30/16	10/4/16	6091182	8.23	ug/L	\$25.00
GHS		X			Y		GHS 31F	Exterior Hose Bib - Grounds Shop Concession Stand	Apex Labora	A6I0419-90	8/31/16	9/30/16	10/4/16	6091182	16.9	ug/L	\$25.00







1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42

43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59

60  
61  
62  
63  
64  
65  
66  
67  
68