


TEST# 1 First Flow	TEST# 2 30 Sec Flush	TEST# 3 After action	Action required Y/N	Passed Below 20/ppi Y/N	Remediation	SAMPLE NAME	BUILDING LOCATION	Lab Name	LAB SAMP ID	SAMPLE DATE	PREP DATE	ANA DATE	BATCH	Result target <20ppb		
														ND= non detect	UNITS	COST PER SAMPLE
KC	X			Y		KC 501	Rm. 1	Apex Laboratories	A6F0114-89	6/1/16	6/6/16	6/7/16	6060139	2.21	ug/L	\$15.00
KC	X			Y		KC 502	Rm. 2	Apex Laboratories	A6F0114-90	6/1/16	6/6/16	6/7/16	6060139	2.02	ug/L	\$15.00
KC	X			Y		KC 503	Rm. 3	Apex Laboratories	A6F0114-91	6/1/16	6/6/16	6/7/16	6060139	2.41	ug/L	\$15.00
KC	X			Y		KC 504	Rm. 4	Apex Laboratories	A6F0114-92	6/1/16	6/6/16	6/7/16	6060139	2.31	ug/L	\$15.00
KC	X			Y		KC 505	Rm. 5	Apex Laboratories	A6F0114-93	6/1/16	6/6/16	6/7/16	6060139	2.34	ug/L	\$15.00
KC	X			Y		KC 506	Rm. 6	Apex Laboratories	A6F0114-94	6/1/16	6/6/16	6/7/16	6060139	2.11	ug/L	\$15.00
KC	X			Y		KC 507	Rm. 7	Apex Laboratories	A6F0114-95	6/1/16	6/6/16	6/7/16	6060139	1.56	ug/L	\$15.00
KC	X			Y		KC 508	Rm. 8	Apex Laboratories	A6F0114-96	6/2/16	6/6/16	6/7/16	6060139	1.36	ug/L	\$15.00
KC	X			Y		KC 509	Rm. 9	Apex Laboratories	A6F0114-97	6/2/16	6/6/16	6/7/16	6060139	2.55	ug/L	\$15.00
KC	X			Y		KC 510	Rm. 10	Apex Laboratories	A6F0114-98	6/2/16	6/6/16	6/7/16	6060139	2.14	ug/L	\$15.00
KC	X			Y		KC 511	Rm. 11	Apex Laboratories	A6F0114-99	6/2/16	6/6/16	6/7/16	6060139	2.15	ug/L	\$15.00
KC	X			Y		KC 512	Rm. 12	Apex Laboratories	A6F0114-AA	6/2/16	6/6/16	6/7/16	6060139	2.19	ug/L	\$15.00
KC	X			Y		KC 513	Rm. 13	Apex Laboratories	A6F0118-01	6/2/16	6/6/16	6/7/16	6060152	1.48	ug/L	\$15.00
KC	X			Y		KC 514	Rm. 14	Apex Laboratories	A6F0118-02	6/2/16	6/6/16	6/7/16	6060152	2.07	ug/L	\$15.00
KC	X			Y		KC 515	Rm. 15	Apex Laboratories	A6F0118-03	6/2/16	6/6/16	6/7/16	6060152	2.24	ug/L	\$15.00
KC	X			Y		KC 516	Rm. 16	Apex Laboratories	A6F0118-04	6/2/16	6/6/16	6/7/16	6060152	1.69	ug/L	\$15.00
KC	X			Y		KC 516A	Fountain ELL/Speech Hall	Apex Laboratories	A6F0118-05	6/2/16	6/6/16	6/7/16	6060152	ND	ug/L	\$15.00
KC	X			Y		KC 516B	Fountain ELL/Speech Hall	Apex Laboratories	A6F0118-06	6/2/16	6/6/16	6/7/16	6060152	0.102	ug/L	\$15.00
KC	X			Y		KC 517	Rm. 17	Apex Laboratories	A6F0118-07	6/2/16	6/6/16	6/7/16	6060152	1.65	ug/L	\$15.00
KC	X			Y		KC 518	Rm. 18	Apex Laboratories	A6F0118-08	6/2/16	6/6/16	6/7/16	6060152	2.16	ug/L	\$15.00
KC	X			Y		KC 519	Rm. 19	Apex Laboratories	A6F0118-09	6/2/16	6/6/16	6/7/16	6060152	1.79	ug/L	\$15.00
KC	X			Y		KC 520	Rm. 20	Apex Laboratories	A6F0118-10	6/2/16	6/6/16	6/7/16	6060152	2.05	ug/L	\$15.00
KC	X			Y		KC 520A	Fountain Gym Hall	Apex Laboratories	A6F0118-11	6/2/16	6/6/16	6/7/16	6060152	0.140	ug/L	\$15.00
KC	X			Y		KC 520B	Fountain Gym Hall	Apex Laboratories	A6F0118-12	6/2/16	6/6/16	6/7/16	6060152	0.158	ug/L	\$15.00
KC	X			Y		KC 521	Kitchen Sink	Apex Laboratories	6/6/16	9/1/16	6/6/16	6/7/16	6060152	5.91	ug/L	\$15.00
KC	X			Y		KC 522	Kitchen Sink	Apex Laboratories	6/6/16	9/1/16	6/6/16	6/7/16	6060152	3.26	ug/L	\$15.00
KC	X			Y		KC 523	Kitchen Sink	Apex Laboratories	6/6/16	9/1/16	6/6/16	6/7/16	6060152	5.61	ug/L	\$15.00
KC	X			Y		KC 550	Courtyard HB - Outside Prod. Rm. Left	Apex Laboratories	9/1/16	9/1/16	10/5/16	10/5/16	6100217	14.8	ug/L	\$25.00
KC		X		Y		KC 550F	Courtyard HB - Outside Prod. Rm. Left	Apex Laboratories	9/1/16	9/1/16	10/5/16	10/5/16	6100217	1.43	ug/L	\$25.00
KC	X			N	abeled not for Drinkin	KC 551	Courtyard HB - Outside Prod. Rm. Right	Apex Laboratories	9/1/16	9/1/16	10/5/16	10/5/16	6100217	32.9	ug/L	\$25.00
KC		X		Y		KC 551F	Courtyard HB - Outside Prod. Rm. Right	Apex Laboratories	9/1/16	9/1/16	10/5/16	10/5/16	6100219	0.644	ug/L	\$25.00
KC	X			Y		KC 552	Ice Maker Refridgerator - Staff Rm.	Apex Laboratories	9/1/16	9/1/16	10/5/16	10/5/16	6100219	0.744	ug/L	\$25.00
KC	X			Y		KC 553	Courtyard Hose Bib - Outside Rm. 22	Apex Laboratories	9/1/16	9/1/16	10/5/16	10/5/16	6100217	15.5	ug/L	\$25.00
KC		X		Y		KC 553F	Courtyard Hose Bib - Outside Rm. 22	Apex Laboratories	9/1/16	9/1/16	10/5/16	10/5/16	6100219	0.500	ug/L	\$25.00
KC	X			Y		KC 554	Exterior Hose Bib - Outside Rm. 21	Apex Laboratories	9/1/16	9/1/16	10/5/16	10/5/16	6100219	16.6	ug/L	\$25.00
KC		X		Y		KC 554F	Exterior Hose Bib - Outside Rm. 21	Apex Laboratories	9/1/16	9/1/16	10/5/16	10/5/16	6100219	ND	ug/L	\$25.00
KC	X			N	abeled not for Drinkin	KC 555	Exterior Hose Bib - Outside Gym	Apex Laboratories	9/1/16	9/1/16	10/5/16	10/5/16	6100219	279	ug/L	\$25.00
KC		X		Y		KC 555F	Exterior Hose Bib - Outside Gym	Apex Laboratories	9/1/16	9/1/16	10/5/16	10/5/16	6100239	0.833	ug/L	\$25.00
KC	X			Y		KC 556	Exterior Hose Bib - Outside Rm. 19 & 20	Apex Laboratories	9/1/16	9/1/16	10/5/16	10/5/16	6100219	12.9	ug/L	\$25.00
KC		X		Y		KC 556F	Exterior Hose Bib - Outside Rm. 19 & 20	Apex Laboratories	9/1/16	9/1/16	10/5/16	10/5/16	6100239	0.278	ug/L	\$25.00
KC	X			Y		KC 557	Exterior Hose Bib - Outside Rm. 23	Apex Laboratories	9/1/16	9/1/16	10/5/16	10/5/16	6100219	19.8	ug/L	\$25.00
KC		X		Y		KC 557F	Exterior Hose Bib - Outside Rm. 23	Apex Laboratories	9/1/16	9/1/16	10/5/16	10/5/16	6100239	0.611	ug/L	\$25.00
KC	X			N	abeled not for Drinkin	KC 558	Exterior Hose Bib - Outside Rm. 3 & 4	Apex Laboratories	9/1/16	9/1/16	10/5/16	10/5/16	6100239	42.6	ug/L	\$25.00
KC		X		Y		KC 558F	Exterior Hose Bib - Outside Rm. 3 & 4	Apex Laboratories	9/1/16	9/1/16	10/5/16	10/5/16	6100239	0.867	ug/L	\$25.00
KC	X			N	abeled not for Drinkin	KC 559	Exterior Hose Bib - Outside Rm. 8	Apex Laboratories	9/1/16	9/1/16	10/5/16	10/5/16	6100239	29.2	ug/L	\$25.00





1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45

46  
47  
48