

WG	TEST# 1 First Flow	TEST# 2 30 Sec Flush	TEST# 3 After action	Action required Y/N	Passed Below 20/ppb Y/N	Remediation	SAMPLE NAME	BUILDING LOCATION	Lab Name	LAB SAMP ID	SAMPLE DATE	PREP DATE	ANA DATE	BATCH	Result target		Number of samples		
															ND= non detect	<20ppb UNITS		COST PER SAMPLE	
WG	X				Y		WG 1	Classroom 4	Apex Labora	A6F0114-15	6/1/16	6/6/16	6/7/16	6060133	0.759	ug/L	\$15.00	1	
WG	X				Y		WG 2	Fountain South Hall East	Apex Labora	A6F0114-16	6/1/16	6/6/16	6/7/16	6060133	2.03	ug/L	\$15.00	2	
WG	X				Y		WG 3	Classroom 3	Apex Labora	A6F0114-17	6/1/16	6/6/16	6/7/16	6060133	0.456	ug/L	\$15.00	3	
WG	X				Y		WG 4	Classroom 2	Apex Labora	A6F0114-18	6/1/16	6/6/16	6/7/16	6060133	1.19	ug/L	\$15.00	4	
WG	X				Y		WG 5	Classroom 1	Apex Labora	A6F0114-19	6/1/16	6/6/16	6/7/16	6060133	0.168	ug/L	\$15.00	5	
WG	X				Y		WG 6	Fountain South Hall West	Apex Labora	A6F0114-20	6/1/16	6/6/16	6/7/16	6060133	0.764	ug/L	\$15.00	6	
WG	X				Y		WG 7	Classroom 5	Apex Labora	A6F0114-21	6/1/16	6/6/16	6/7/16	6060135	0.477	ug/L	\$15.00	7	
WG	X				Y		WG 8	Classroom 6	Apex Labora	A6F0114-22	6/1/16	6/6/16	6/7/16	6060135	3.41	ug/L	\$15.00	8	
WG	X				Y		WG 9	Fountain East Hall	Apex Labora	A6F0114-23	6/1/16	6/6/16	6/7/16	6060135	1.60	ug/L	\$15.00	9	
WG	X				Y		WG 10	Classroom 7	Apex Labora	A6F0114-24	6/1/16	6/6/16	6/7/16	6060135	0.802	ug/L	\$15.00	10	
WG	X				Y		WG 11	Classroom 8	Apex Labora	A6F0114-25	6/1/16	6/6/16	6/7/16	6060135	1.21	ug/L	\$15.00	11	
WG	X				Y		WG 12	Classroom 9	Apex Labora	A6F0114-26	6/1/16	6/6/16	6/7/16	6060135	2.60	ug/L	\$15.00	12	
WG	X				Y		WG 13	Classroom 10	Apex Labora	A6F0114-27	6/1/16	6/6/16	6/7/16	6060135	0.214	ug/L	\$15.00	13	
WG	X				Y		WG 14	Fountain North Hall	Apex Labora	A6F0114-28	6/1/16	6/6/16	6/7/16	6060135	0.139	ug/L	\$15.00	14	
WG	X				Y		WG 101	Sink Middle	Apex Labora	A6F0114-01	6/1/16	6/6/16	6/7/16	6060133	4.77	ug/L	\$15.00	15	
WG	X				Y		WG 102	Sink West	Apex Labora	A6F0114-02	6/1/16	6/6/16	6/7/16	6060133	0.743	ug/L	\$15.00	16	
WG	X				Y		WG 103	Fountain Basement East	Apex Labora	A6F0114-03	6/1/16	6/6/16	6/7/16	6060133	0.605	ug/L	\$15.00	17	
WG	X				Y		WG 104	Fountain Basement West	Apex Labora	A6F0114-04	6/1/16	6/6/16	6/7/16	6060133	0.502	ug/L	\$15.00	18	
WG	X				Y		WG 105	Classroom 17	Apex Labora	A6F0114-05	6/1/16	6/6/16	6/7/16	6060133	10.2	ug/L	\$15.00	19	
WG		X			Y		WG 105 6/16F	Classroom 17	Apex Labora	A6F0629-27	6/20/16	6/27/16	6/28/16	6060794	0.967	ug/L	\$15.00	20	
WG	X				Y		WG 106	Classroom 18	Apex Labora	A6F0114-06	6/1/16	6/6/16	6/7/16	6060133	12.2	ug/L	\$15.00	21	
WG		X			Y		WG 106 6/16F	Classroom 18	Apex Labora	A6F0629-28	6/20/16	6/27/16	6/28/16	6060794	2.17	ug/L	\$15.00	22	
WG	X				Y		WG 107	Classroom 16	Apex Labora	A6F0114-07	6/1/16	6/6/16	6/7/16	6060133	0.186	ug/L	\$15.00	23	
WG	X				Y		WG 108	Classroom 15	Apex Labora	A6F0114-08	6/1/16	6/6/16	6/7/16	6060133	1.18	ug/L	\$15.00	24	
WG	X				Y		WG 109	Classroom 14	Apex Labora	A6F0114-09	6/1/16	6/6/16	6/7/16	6060133	2.96	ug/L	\$15.00	25	
WG	X				Y		WG 110	Classroom 13	Apex Labora	A6F0114-10	6/1/16	6/6/16	6/7/16	6060133	0.477	ug/L	\$15.00	26	
WG	X				Y		WG 111	Fountain	Apex Labora	A6F0114-11	6/1/16	6/6/16	6/7/16	6060133	0.859	ug/L	\$15.00	27	
WG	X				Y		WG 112	Classroom 12	Apex Labora	A6F0114-12	6/1/16	6/6/16	6/7/16	6060133	7.01	ug/L	\$15.00	28	
WG	X				Y		WG 113	Health Rm.	Apex Labora	A6F0114-13	6/1/16	6/6/16	6/7/16	6060133	0.537	ug/L	\$15.00	29	
WG	X				Y		WG 114	Classroom 11	Apex Labora	A6F0114-14	6/1/16	6/6/16	6/7/16	6060133	5.45	ug/L	\$15.00	30	
WG	X				Y		WG 115 1ST	Extt Hose Bib - Outside Rm. 2	Apex Labora	A6I0419-60	8/3/16	9/30/16	10/4/16	6091181	4.13	ug/L	\$25.00	31	
WG		X			Y		WG 115 2ND	Ext Hose Bib - Outside Rm. 2	Apex Labora	A6I0419-63	8/3/16	9/30/16	10/4/16	6091181	0.678	ug/L	\$25.00	32	
WG	X				Y		WG 116 1ST	Ext Hose Bib - Outside Rm. 7	Apex Labora	A6I0419-61	8/3/16	9/30/16	10/4/16	6091181	17.8	ug/L	\$25.00	33	
WG		X			Y		WG 116 2ND	Ext Hose Bib - Outside Rm. 7	Apex Labora	A6I0419-64	8/3/16	9/30/16	10/4/16	6091181	4.88	ug/L	\$25.00	34	
WG	X				Y		WG 117 1ST	Ext Hose Bib - Principal's Office	Apex Labora	A6I0419-62	8/3/16	9/30/16	10/4/16	6091181	1.22	ug/L	\$25.00	35	
WG		X			Y		WG 117 2ND	Ext Hose Bib - Principal's Office	Apex Labora	A6I0419-65	8/3/16	9/30/16	10/4/16	6091181	ND	ug/L	\$25.00	36	
																		\$600.00	